

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

1) OWNER: LAUDERDALE, TOMMY ADDRESS: 103 DAVID LANE CITY: PLEASANTON STATE: TX ZIP: 78064-

2) ADDRESS OF WELL:

County: BLANCO GRID # 57-45-6
Street or RFD: LOS ENCINOS HWY 281
City, State, Zip code: JOHNSON CITY TX 78636-

5)

3) TYPE OF WORK: NEW WELL

4) PROPOSED USE: DOMESTIC
If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 00546

DIAMETER OF HOLE		
DIAMETER	FROM	TO
8.62	0	60
6.75	60	83
6.0	83	322

7) DRILLING METHOD:

AIR HAMMER

8) BOREHOLE COMPLETION:

STRAIGHT WALL

IF GRAVEL... FROM FT. TO FT.
FROM FT. TO FT.

DATE DRILLING:

STARTED: 05/09/96
COMPLETED: 05/09/96

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PLASTIC SOLID	0	61	.280

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	1	BROWN TOPSOIL
1	15	WHITE CALICHE
15	29	YELLOW CLAY
29	40	RED CLAY
40	42	WHITE AND RED LIMESTONE
42	45	WHITE LIMESTONE WITH CAVE
45	58	WHITE LIMESTONE
58	116	WHITE AND RED LIMESTONE
116	128	OILY GRAY LIMESTONE
128	147	WHITE AND RED LIMESTONE
147	159	OILY GRAY LIMESTONE
159	174	WHITE AND RED LIMESTONE
174	183	OILY GRAY LIMESTONE
183	322	WHITE AND RED LIMESTONE

9) CEMENTING DATA:

Cemented from No. of Sacks Used
0 FT. TO 18 FT. 1
45 FT. TO 60 FT. 2
Method used: GRAVITY CEMENTED
Cemented by: L & L DRILLING CO
Distance to septic field lines: 800 ft.
Method of verification of above distance:
ESTIMATED

10) SURFACE COMPLETION:

SPEC. STEEL SLEEVE

11) WATER LEVEL:

STATIC LEVEL : 82 FT. DATE: 05/09/96
ARTESIAN FLOW: GPM. DATE:

12) PACKERS:

TYPE	DEPTH
-----	---
-----	---
-----	---

13) TYPE PUMP:

DEPTH TO PUMP:

14) WELL TEST:

JETTED

YIELD: 50 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:

TYPE OF WATER: NO STRATA OF UNDESIRABLE WATER PENETRATED

DEPTH OF STRATA:

CHEMICAL ANALYSIS MADE
15 GRAINS OF HARDNESS
330 T.D.S.

COMPANY NAME: L & L DRILLING CO.
ADDRESS: DRAWER 217

WATER WELL DRILLER'S LICENSE NO.: 1595
CITY: HYE, STATE: TX ZIP CODE: 78635

FOR TWC USE ONLY
WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed)

Gregory A. Smith
(LICENSED WATER WELL DRILLER)

(signed)

(REGISTERED DRILLER TRAINEE)

STATE OF TEXAS WATER WELL REPORT (PAGE 2)

OWNER: LAUDERDALE, TOMMY

ADDRESS: 103 DAVID LAKE

CITY: PLEASANTON

STATE: TX ZIP: 78064-

WATER DEPTH/YIELD:

FROM TO YIELD

42 45 WATER-DRIED-UP

136 137 2 GPM

246 247 1 GPM

254 255 3 GPM

280 282 22 GPM

296 297 22 GPM

WELL JETTING INFORMATION:

JETTED AT YIELD

160 FT. 30 GPM.